



DEVELOPMENT SERVICES CENTER
PUBLIC WORKS DEPARTMENT
17575 PEAK AVENUE
MORGAN HILL, CA 95037-5301
ENGINEERING: 408-778-6480
FAX: 408-779-7236
WWW.MORGANHILL.CA.GOV

ADDENDUM NO. 1

DATE: March 22, 2018

TO: ALL PLAN HOLDERS OF THE:

2018 INFLOW AND INFILTRATION PROJECT

FROM: KEVIN O'CONNELL – CITY OF MORGAN HILL

SUBJECT: CLARIFICATIONS

CLARIFICATION

Piping used for bursting process shall be High Density Polyethylene (HDPE) SDR 17 butt welded piping as stated in SECTION 109 - SANITARY SEWER SYSTEM

UNDER " TECHNICAL SPECIFICATIONS"

ADD TO SECTION 110, PART 2 – PRODUCTS, ITEMS "A AND B":

"An Approved Equal shall include: Strong-Seal QSR Patching Material and Neopoxy 50-Year Design Life Structural Liner (NPR-3200, NPR-5300 and NPR-3501)

ADDENDUM ACKNOWLEDGMENT

Bidder acknowledges receipt of this addendum, which shall be attached to the proposal.

Contractor's Representative / Date

**THIS DOCUMENT AND THE ATTACHMENTS SHALL BECOME PART OF THE
PROJECTS SPECIFICATION**